

CHAPTER 4 WASTEWATER QUANTITY

WATER CONSUMPTION RATE

City (> 10 000 persons)

- 230 – 320 litre/person/day

Suburban


- 130 – 230 litre/person/day

Heavy Industries

- 45 000 litre/ha/day

Light Industries

- 22 000 litre/ha/day





Demand.....



Wastewater production.....

Wastewater quantity varies hourly, daily and weekly.

Peak flow occurs at maximum flow for the day.

DEFINITIONS

Sewage

- any liquid discharge normally from domestic sources

Sewer

- any line of pipes or channels used to convey sewage and effluents

Sewage Treatment Plant (STP)

- a site designed to treat sewage

Sewerage system

- a system incorporating sewers intended for the collection, transportation, pumping, treatment and disposal of sewage

POPULATION EQUIVALENT (PE)

- **The equivalent, in terms of fixed population of a varying or transient population or other activity eg. industrial or commercial contributing flow to the sewerage system.**
- **PE depends on type of premise and activity**



5

PE per UNIT



3 PE

per 100 m²
of
FLOOR
AREA



0.2

PE per STUDENT
Day school



SEKOLAH KERANGSAHAN KUALA BALAH


WELCOME

SEKOLAH KERANGSAHAN KUALA BALAH

1

PE per STUDENT
Residential school

4 PE per
BED





PAN PACIFIC

Manila

4 PE
per ROOM

A photograph of a large industrial facility, likely a factory or refinery. The scene is filled with complex machinery, including large pipes, structural steel beams, and various pieces of equipment. The lighting is dramatic, with bright light coming from a high window on the right, creating strong shadows and highlights. The overall atmosphere is one of a busy, large-scale industrial operation.

0.3 PE per
STAFF

0.5

PE per
PERSON






0.2 PE

per PERSON

| Type of Establishment/Premise | Population Equivalent (PE) |
|--|--|
| Residential | 5 per house |
| Commercial | 3 per 100m ² area |
| Educational Institutions - Day Schools - Residential Schools | 0.2 per student 1 per student (residential) |
| Hospitals | 4 per bed |
| Hotels | 4 per room |
| Factories | 0.3 per employee |
| Market (Wet Type) | 3 per stall |
| Market (Dry Type) | 1 per stall |
| Petrol Stations | 18 per service bay |
| Bus Terminal | 4 per bus bay |
| Taxi Terminal | 4 per taxi bay |
| Mosque | 0.5 per person |

| Type of Establishment/Premise | Population Equivalent (PE) |
|---------------------------------|----------------------------|
| Church or Temple | 0.2 per person |
| Stadium | 0.2 per person |
| Swimming Pool or Sports Complex | 0.5 per person |
| Public Toilet | 16 per WC (water closet) |
| Airport | 0.2 per passenger/day |
| Airport | 0.3 per employee |
| Laundry | 10 per machine |
| Prison | 1 per person |
| Golf Course | 20 per hole |

FLOW RATE (L/min)



- Varies hourly, daily and weekly
- Peak flow occurs at maximum flow for the day

Design flow rate

225

Litres/capita/day (lpcd)

Average daily flow = Design flow rate x PE

Peak Flow Factor (PFF) = $4.7 p^{-0.11}$

[where p is population equivalent (PE) in thousand]

Peak Flow = PFF x average daily flow

EXAMPLE

A new residential area consists of the following premises:

| <u>Premise</u> | <u>Unit / Area</u> |
|---------------------|----------------------|
| Residential house | 3200 units |
| Commercial building | 10000 m ² |
| Primary school | 800 students |
| Private hospital | 120 beds |

Calculate the average daily flow of sewage and the peak flow rate from the residential area.

SOLUTION

Determine the total PE:

| Premise | Unit / Area | PE |
|---------------------|-----------------------|---------------------------|
| Residential house | 3200 units | $3200 \times 5 = 16000$ |
| Commercial building | 10 000 m ² | $10000 \times 0.03 = 300$ |
| Primary school | 800 students | $800 \times 0.2 = 160$ |
| Private hospital | 120 beds | $120 \times 4 = 480$ |
| | | Total PE = 16940 |

$$\begin{aligned}\text{Average daily flow} &= 16940 \times 225 \text{ lpcd} \\ &= 3811.5 \text{ m}^3/\text{day}\end{aligned}$$

$$\begin{aligned}\text{Peak Flow Factor} &= 4.7 (16.940)^{-0.11} \\ &= 4.7 \times 0.733 \\ &= 3.445\end{aligned}$$

$$\begin{aligned}\text{Peak flow rate} &= 3.445 \times 3811.5 \text{ m}^3/\text{day} \\ &= 13131 \text{ m}^3/\text{day}\end{aligned}$$

